

County of  
PALM BEACH, FLORIDA

Codified through Ord. No. 06-042, adopted Oct. 17, 2006.  
(Supplement No. 56)

**CODE OF LAWS  
AND ORDINANCES RELATING TO  
PALM BEACH COUNTY  
GOVERNMENT**

Article IV: FIRE CODE

Chapter 10

General Provisions

10.23 In all new and existing buildings and structures, a minimum radio signal strength of  $-102.0$  dBm (1.78 micro volts) in the frequency band of 806-824/851-869 MHz shall be maintained. Where this signal strength cannot be achieved, an 800 MHz bi-directional amplified system shall be installed to meet minimum radio signal strength required for effective emergency communications.